

In October of 2016, Oconomowoc Utilities met with OASD staff to discuss the sampling of the drinking fountains at the City served schools for lead. It was determined to sample the closest, most frequently used drinking fountain in closest proximity to the main entrance of the school.

The sample bottles and results were provided by Northern Lakes Service, Inc and were Collected by Utility staff with the assistance of the OASD Buildings & Grounds staff

Samples were collected on Sunday November 6, 2016 between the times of 7:00am and 8:15am

The results of the Lead/Copper water sampling were as follows:

<u>School</u>	<u>Lead (ug/L)</u>	<u>Copper (ug/L)</u>
High School	No Detect	540
Silver Lake	0.2	870
Nature Hill	No Detect	520
Greenland	1.5	350
Parklawn	0.63	330
Summit	No Detect	480

Note - the Maximum Contaminat Level or Action Level for Lead is 15 ug/L and for Copper is 1300 ug/L

Note - these sites are not part of the WDNR approved Lead/Copper locations (60)